

Komponent	Resultat	Enhed	DL	Metode	Um (%)
Coliforme bakterier 37°C	< 1	MPN/100 ml	1	ISO 9308-2:2012	0.25σ
Escherichia coli	< 1	MPN/100 ml	1	ISO 9308-2:2012	0.25σ
Intestinale Enterokokker	< 1	CFU/100 ml	1	ISO 7899-2:2000	0.11σ
Kimtal ved 22°C	< 1	CFU/ml	1	ISO 6222:1999	0.15σ
Nitrit	< 0,001	mg/l	0,001	DS/EN ISO 15923-1:2024, mod.	15
Akkrediteret prøvetagning	Ja			DS ISO 5667-5:2006,MST - Drikkevand. Manual f	
Prøvetagning efter flush	Udført			DS ISO 5667-5:2006,DS/EN ISO 19458:2006,MS	
Vandtemperatur	14,6	°C		DS/EN ISO 19458:2006	

SC1008
1194
1229
1218
1686
243
pr prøvetagning(v6,2025) N/A
F - Drikkevand. Manual for prøvetagning(v6,2025) N/A
1154